PERMIT-Subsurface Sewage Disposal

Public Health
Prevent. Promote. Protect.
Idaho Public Health Districts

Eastern Idaho Public Health District
1250 Hollipark Drive
Idaho Falls ID 83401
(208) 523-5382

Permit # : 1912029
Date : 11/28/2012
Parcel # : RP17N20E15002
Doc ID # :

Applicant's Name: Marty Halpern
Owners Name: Marty Halpern
Property Address: XXXX Hat Creek Road ELLIS ID 83235
Legal Description: Township 17N Range 20E Section 15
Subdivision: Tolman Lot Split Lot B Block Size(acres): 28.0

Type of Installation	Type of System (check all that apply)			Water Supply
☒ New System ☐ Expansion ☐ Repair ☐ Tank Only	☐ Absorption Bed ☐ Capping Fill ☐ Central System ☐ Composting Toilet ☐ Drip Distribution ☐ ETPS ☐ Experimental ☐ Extra Drainrock ☐ Evapotranspiration ☐ Gravel Drainfield	☐ Gravelless Drainfield ☐ Gray Water Sump ☐ Gray Water System ☐ Holding Tank ☐ Incinerator Toilet ☐ Individual Lagoon ☐ Intermittent SF ☐ Intrench SF ☐ LSAS ☐ Pit Privy	☒ Pressurized DF ☐ Recirculating GF ☐ RV Dump Station ☐ Sand Mound ☐ Seepage Pit ☐ Steep Slope Drainfield ☐ Two Cell Lagoon ☐ Vault Privy ☐ Other (see below)	☒ Private ☐ Shared ☐ Public **Water Source** ☒ Well ☐ Spring
☐ Basic System ☒ Complex System				

Conditions of Approval:

Follow engineering plans and specifications. If any changes need to be made contact engineer and health department for written approvals.

☒ Residential permit — 1 Bedrooms

☐ Non-residential permit — 150.0 Gallons Per Day ____ Gallons Per Day

Soil Type: B-1 USDA
The minimum septic tank capacity is: 1000 Gallons
The minimum effective drainfield absorption area is: 300 Square Feet
The drainfeld can be no closer to permanent/intermittent surface water than: 200 Feet

Note: (Final approval of this permit requires inspection of the uncovered system.)

All plans, specifications, and conditions contained in the approved permit application are hereby incorporated into, and are enforceable as part of the permit. The permit will expire one (1) year from date of issuance. The permit may be renewed if the renewal is applied for on or before the expiration date.

Steve Adler
EHS Permit Issued Signature

09
EHS Code

11/28/2012
Date

Revision Date: 06/17/2010